


This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND

— BRANCH IDENTIFIER	
RW01:10	— SECTION IDENTIFIER
— SECTION BOUNDARY	
	PCI 86–100 GOOD
	PCI 71–85 SATISFACTORY
	PCI 56–70 FAIR
	PCI 41–55 POOR
	PCI 26–40 VERY POOR
	PCI 11–25 SERIOUS
	PCI 0–10 FAILED

CURRENT 2024 PAVEMENT CONDITION INDEX


Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
RW18	11	Runway 18-36	AAC	315,000	0	1/1/2025	1/1/2025	100	Good
TW	11	Taxiway	AC	170,450	25.3	8/1/1999	10/2/2024	61	Fair
TW	12	Taxiway	AC	32,925	25.3	8/1/1999	10/2/2024	60	Fair
TW	14	Taxiway	AC	23,875	21.3	8/1/2003	10/2/2024	84	Satisfactory
AP	03	Apron	AC	40,638	6.4	6/28/2018	10/2/2024	93	Good
AP	11	Apron	AC	199,475	26.3	8/1/1998	10/2/2024	50	Poor

AIRFIELD PAVEMENT WORK HISTORY

1. FAAP-01, 1966
2. AIP-001-1983, OVERLAY AND EXTEND RUNWAY 18/36; CONSTRUCT TURNAROUNDS; OVERLAY AND EXPAND CONNECTING TAXIWAY AND APRON.
3. AIP-002-1998, REHABILITATE AND WIDEN RUNWAY; REHABILITATE CONNECTING TAXIWAY AND PORTION OF APRON.
4. AIP-003-1999, CONSTRUCT PARALLEL, CONNECTING AND HANGAR ACCESS TAXIWAYS (TW:11,TW:12).
5. AIP-004, 2003, CONSTRUCT HANGAR TAXIWAY E (TW:14); CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
6. AIP-005-2007, CONSTRUCT SELF-FUELING APRON (AP:03).
7. AIP-007-2015, CRACK SEAL, SEAL COAT, AND REMARK ALL PAVEMENTS [INSPECTED PRIOR TO PROJECT].
8. AIP-009-2017, RECONSTRUCT EXISTING APRON (AP:03).
9. AIP-014-2022, CRACK SEAL, SEAL COAT, AND REMARK ALL TAXIWAYS (TW:11, TW:12, TW:14).
10. AIP-015-2024, REHABILITATE RUNWAY (RW18:11).



This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kimley-Horn and Associates, Inc. shall be without liability to Kimley-Horn and Associates, Inc.



LEGEND


- BRANCH IDENTIFIER
- RW01:10** — SECTION IDENTIFIER
- SECTION BOUNDARY
- PCI 86-100 GOOD
- PCI 71-85 SATISFACTORY
- PCI 56-70 FAIR
- PCI 41-55 POOR
- PCI 26-40 VERY POOR
- PCI 11-25 SERIOUS
- PCI 0-10 FAILED

FORECASTED PAVEMENT CONDITION INDEX

Branch ID	Section ID	Surface Type	Current PCI (2024)	2025	2026	2027	2028	2029
RW18	11	AAC	100	100	97	93	91	88
TW	11	AC	61	61	59	57	55	53
TW	12	AC	60	60	58	56	54	51
TW	14	AC	84	84	82	80	79	78
AP	03	AC	93	92	90	87	85	83
AP	11	AC	50	49	47	45	42	39



This document, together with the concepts and designs presented herein, as an instrument of service, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinley-Horn and Associates, Inc. shall be without liability to Kinley-Horn and Associates, Inc.



LEGEND

— BRANCH IDENTIFIER
RW01:10 SECTION IDENTIFIER
 — SECTION BOUNDARY

MAJOR REHABILITATION		GLOBAL TREATMENT
	2025	
	2026	
	2027	
	2028	
	2029	

5-YEAR PAVEMENT NEEDS BY SECTION

Year	Branch ID	Section ID	Surface Type	Section Area (SF)	PCI at Treatment	Recommended Treatment	Treatment Category
2025	TW	11	AC	170,450	61	Mill and Overlay	Major Rehabilitation
2025	TW	12	AC	32,925	60	Mill and Overlay	Major Rehabilitation
2025	AP	03	AC	40,638	92	Crack Seal and Seal Coat	Global Treatment
2025	AP	11	AC	199,475	49	Full-Depth Reconstruction	Major Rehabilitation
2027	TW	14	AC	23,875	80	Crack Seal and Seal Coat	Global Treatment

Taxiway



TW-11-26: L&T Cracking



TW-12-07: Overview

Apron



AP-03-04: Weathering



AP-11-21: Overview



AP-11-34: Alligator Cracking



AP-11-34: Swelling

Re-Inspection Report

MDT SASP 2024

Generated Date 1/7/2025

Page 1 of 7

Network: 8S1 **Name:** Polson Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 240,113 SqFt

Section: 03 of 2 **From:** A-11 **To:** HANGARS **Last Const.:** 6/28/2018

Surface: AC **Family:** _MDT2024 - AP AC **Zone:** **Category:** **Rank:** P

Area: 40,638 SqFt **Length:** 260 Ft **Width:** 206 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 6/28/2018 **Work Type:** New Construction - AC **Code:** NC-AC **Is Major M&R:** True

Last Insp. Date: 10/2/2024 **Total Samples:** 9 **Surveyed:** 4

Conditions: PCI: 93

Inspection Comments:

Sample Number: 1 **Type:** R **Area:** 4887.00 SqFt **PCI:** 93

Sample Comments:

42 BLEEDING N 10.00 SqFt
57 WEATHERING L 4887.00 SqFt

Sample Number: 3 **Type:** R **Area:** 4900.00 SqFt **PCI:** 91

Sample Comments:

45 DEPRESSION L 21.00 SqFt
57 WEATHERING L 4900.00 SqFt

Sample Number: 4 **Type:** R **Area:** 4429.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 4429.00 SqFt

Sample Number: 6 **Type:** R **Area:** 4900.00 SqFt **PCI:** 94

Sample Comments:

57 WEATHERING L 4900.00 SqFt

Network:	8S1	Name:	Polson Airport						
Branch:	AP	Name:	Apron	Use:	APRON	Area:	240,113 SqFt		
Section:	11	of	2	From:	ENTIRE APRON	To:	Last Const.: 8/1/1998		
Surface:	AC	Family:	_MDT2024 - AP AC	Zone:		Category:	D	Rank:	P
Area:	199,475 SqFt	Length:	775 Ft	Width:	245 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACN	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/1998	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Last Insp. Date:	10/2/2024	TotalSamples:	40	Surveyed:	6				
Conditions:	PCI: 50								
Inspection Comments:									
Sample Number:	14	Type:	R	Area:	1900.00 SqFt	PCI:	45		
Sample Comments:									
45	DEPRESSION	L	28.00	SqFt					
48	L & T CR	L	316.00	Ft					
48	L & T CR	M	28.00	Ft					
50	PATCHING	L	108.00	SqFt					
57	WEATHERING	L	896.00	SqFt					
57	WEATHERING	M	896.00	SqFt					
Sample Number:	21	Type:	R	Area:	4900.00 SqFt	PCI:	54		
Sample Comments:									
48	L & T CR	L	882.00	Ft					
48	L & T CR	M	44.00	Ft					
57	WEATHERING	L	4165.00	SqFt					
57	WEATHERING	M	735.00	SqFt					
Sample Number:	27	Type:	R	Area:	4900.00 SqFt	PCI:	63		
Sample Comments:									
48	L & T CR	L	649.00	Ft					
57	WEATHERING	L	4165.00	SqFt					
57	WEATHERING	M	735.00	SqFt					
Sample Number:	34	Type:	R	Area:	5700.00 SqFt	PCI:	29		
Sample Comments:									
43	BLOCK CR	L	5700.00	SqFt					
45	DEPRESSION	L	50.00	SqFt					
52	RAVELING	L	1425.00	SqFt					
56	SWELLING	L	30.00	SqFt					
56	SWELLING	M	186.00	SqFt					
56	SWELLING	H	189.00	SqFt					
57	WEATHERING	L	4275.00	SqFt					
Sample Number:	35	Type:	R	Area:	4900.00 SqFt	PCI:	56		
Sample Comments:									
48	L & T CR	L	763.00	Ft					
48	L & T CR	M	70.00	Ft					
57	WEATHERING	L	3920.00	SqFt					
57	WEATHERING	M	980.00	SqFt					
Sample Number:	7	Type:	R	Area:	4900.00 SqFt	PCI:	55		
Sample Comments:									
48	L & T CR	L	778.00	Ft					
48	L & T CR	M	18.00	Ft					
57	WEATHERING	L	4165.00	SqFt					
57	WEATHERING	M	735.00	SqFt					

Network:	8S1	Name:	Polson Airport				
Branch:	RW18	Name:	Runway 18-36	Use:	RUNWAY	Area:	315,000 SqFt
Section:	11	of 1	From:	STA 10+00	To:	STA 52+00	Last Const.: 1/1/2025
Surface:	AAC	Family:	_MDT2024 - RW AC AAC	Zone:		Category:	D
Area:	315,000 SqFt	Length:	4,200 Ft	Width:	75 Ft	Rank:	P
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0
Section Comments:							
Work Date:	8/1/1998	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R: True
Work Date:	1/1/2025	Work Type:	Mill and Overlay		Code:	ML-OL	Is Major M&R: True
Last Insp. Date:	9/6/2021	TotalSamples:	65	Surveyed:	8		
Conditions:	PCI: 47	NOTE: *** Pre-Construction PCI ***					
Inspection Comments:							
Sample Number:	05	Type:	R	Area:	4875.00 SqFt	PCI:	50
Sample Comments:							
45	DEPRESSION	L	48.00	SqFt			
48	L & T CR	L	596.00	Ft			
48	L & T CR	M	26.00	Ft			
56	SWELLING	L	60.00	SqFt			
57	WEATHERING	L	3656.00	SqFt			
57	WEATHERING	M	1219.00	SqFt			
Sample Number:	15	Type:	R	Area:	4875.00 SqFt	PCI:	49
Sample Comments:							
48	L & T CR	L	825.00	Ft			
48	L & T CR	M	18.00	Ft			
56	SWELLING	L	222.00	SqFt			
57	WEATHERING	L	3900.00	SqFt			
57	WEATHERING	M	975.00	SqFt			
Sample Number:	25	Type:	R	Area:	4875.00 SqFt	PCI:	54
Sample Comments:							
48	L & T CR	L	733.00	Ft			
48	L & T CR	M	7.00	Ft			
56	SWELLING	L	54.00	SqFt			
57	WEATHERING	L	3900.00	SqFt			
57	WEATHERING	M	975.00	SqFt			
Sample Number:	34	Type:	A	Area:	4875.00 SqFt	PCI:	39
Sample Comments:							
48	L & T CR	L	629.00	Ft			
48	L & T CR	M	12.00	Ft			
50	PATCHING	L	450.00	SqFt			
50	PATCHING	H	450.00	SqFt			
57	WEATHERING	M	820.00	SqFt			
Sample Number:	35	Type:	R	Area:	4875.00 SqFt	PCI:	54
Sample Comments:							
48	L & T CR	L	858.00	Ft			
48	L & T CR	M	59.00	Ft			
57	WEATHERING	L	3900.00	SqFt			
57	WEATHERING	M	975.00	SqFt			
Sample Number:	45	Type:	R	Area:	4875.00 SqFt	PCI:	53
Sample Comments:							
48	L & T CR	L	647.00	Ft			
48	L & T CR	M	86.00	Ft			
56	SWELLING	L	96.00	SqFt			
57	WEATHERING	L	3900.00	SqFt			
57	WEATHERING	M	975.00	SqFt			

Sample Number: 55 **Type:** R **Area:** 4875.00 SqFt **PCI:** 54

Sample Comments:

48	L & T CR	L	578.00	Ft
48	L & T CR	M	30.00	Ft
56	SWELLING	L	130.00	SqFt
57	WEATHERING	L	3413.00	SqFt
57	WEATHERING	M	1462.00	SqFt

Sample Number: 63 **Type:** R **Area:** 4875.00 SqFt **PCI:** 16

Sample Comments:

45	DEPRESSION	L	1300.00	SqFt
45	DEPRESSION	M	1625.00	SqFt
48	L & T CR	L	1008.00	Ft
48	L & T CR	M	29.00	Ft
57	WEATHERING	L	3413.00	SqFt
57	WEATHERING	M	1462.00	SqFt

Network:	8S1	Name:	Polson Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	227,250 SqFt		
Section:	11	of 3	From:	R-11 PARALLEL TW	To:	A-11	Last Const.:	8/1/1999	
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	D	Rank:	P
Area:	170,450 SqFt	Length:	4,870 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/1999	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2022	Work Type:	Surface Seal - Seal Coat		Code:	SS-SC	Is Major M&R:	False	
Last Insp. Date:	10/2/2024	TotalSamples:	35	Surveyed:	5				
Conditions:	PCI: 61								
Inspection Comments:									
Sample Number:	12	Type:	R	Area:	5075.00 SqFt	PCI:	60		
Sample Comments:									
48	L & T CR	L	829.00	Ft					
48	L & T CR	M	13.00	Ft					
57	WEATHERING	L	2538.00	SqFt					
Sample Number:	19	Type:	R	Area:	5075.00 SqFt	PCI:	61		
Sample Comments:									
45	DEPRESSION	L	4.00	SqFt					
48	L & T CR	L	843.00	Ft					
48	L & T CR	M	6.00	Ft					
57	WEATHERING	L	2538.00	SqFt					
Sample Number:	26	Type:	R	Area:	5075.00 SqFt	PCI:	65		
Sample Comments:									
48	L & T CR	L	581.00	Ft					
48	L & T CR	M	20.00	Ft					
57	WEATHERING	L	2538.00	SqFt					
Sample Number:	33	Type:	R	Area:	3238.00 SqFt	PCI:	60		
Sample Comments:									
48	L & T CR	L	543.00	Ft					
48	L & T CR	M	10.00	Ft					
57	WEATHERING	L	1619.00	SqFt					
Sample Number:	5	Type:	R	Area:	5075.00 SqFt	PCI:	60		
Sample Comments:									
48	L & T CR	L	845.00	Ft					
48	L & T CR	M	10.00	Ft					
57	WEATHERING	L	2538.00	SqFt					

Network:	8S1	Name:	Polson Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	227,250 SqFt		
Section:	12	of 3	From:	R-11	To:	HANGARS	Last Const.:	8/1/1999	
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:		Category:	D	Rank:	P
Area:	32,925 SqFt	Length:	1,317 Ft	Width:	25 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/1999	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2022	Work Type:	Surface Seal - Seal Coat		Code:	SS-SC	Is Major M&R:	False	
Last Insp. Date:	10/2/2024	TotalSamples:	9	Surveyed:	4				
Conditions:	PCI: 60								
Inspection Comments:									
Sample Number:	2	Type:	R	Area:	3875.00 SqFt	PCI:	56		
Sample Comments:									
45	DEPRESSION	L		9.00	SqFt				
48	L & T CR	L		1174.00	Ft				
57	WEATHERING	L		1938.00	SqFt				
Sample Number:	5	Type:	R	Area:	3625.00 SqFt	PCI:	61		
Sample Comments:									
45	DEPRESSION	L		8.00	SqFt				
48	L & T CR	L		746.00	Ft				
57	WEATHERING	L		1812.00	SqFt				
Sample Number:	7	Type:	R	Area:	4206.00 SqFt	PCI:	64		
Sample Comments:									
48	L & T CR	L		522.00	Ft				
48	L & T CR	M		13.00	Ft				
57	WEATHERING	L		2103.00	SqFt				
Sample Number:	8	Type:	R	Area:	3625.00 SqFt	PCI:	57		
Sample Comments:									
48	L & T CR	L		720.00	Ft				
48	L & T CR	M		28.00	Ft				
57	WEATHERING	L		1812.00	SqFt				

Network:	8S1	Name:	Polson Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	227,250 SqFt		
Section:	14	of 3	From:	T-12	To:	HANGARS	Last Const.:	8/1/2003	
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:	POLS	Category:	D	Rank:	P
Area:	23,875 SqFt	Length:	955 Ft	Width:	25 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2003	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2022	Work Type:	Surface Seal - Seal Coat		Code:	SS-SC	Is Major M&R:	False	
Last Insp. Date:	10/2/2024	TotalSamples:	5	Surveyed:	3				
Conditions:	PCI:	84							
Inspection Comments:									
Sample Number:	1	Type:	R	Area:	4879.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	107.00	Ft					
50	PATCHING	L	1020.00	SqFt					
57	WEATHERING	L	3859.00	SqFt					
Sample Number:	3	Type:	R	Area:	4732.00 SqFt	PCI:	91		
Sample Comments:									
48	L & T CR	L	12.00	Ft					
57	WEATHERING	L	4732.00	SqFt					
Sample Number:	5	Type:	R	Area:	4732.00 SqFt	PCI:	94		
Sample Comments:									
57	WEATHERING	L	4732.00	SqFt					