


This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND

BRANCH IDENTIFIER
SECTION IDENTIFIER
SECTION BOUNDARY

	PCI 86-100 GOOD
	PCI 71-85 SATISFACTORY
	PCI 56-70 FAIR
	PCI 41-55 POOR
	PCI 26-40 VERY POOR
	PCI 11-25 SERIOUS
	PCI 0-10 FAILED

CURRENT 2024 PAVEMENT CONDITION INDEX

Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
RW02	03	Runway 02-20	AAC	174,000	21.3	8/1/2003	10/16/2024	71	Satisfactory
RW12	01	Runway 12-30	AAC	465,000	17.3	8/1/2007	10/16/2024	67	Fair
RW12	02	Runway 12-30	AAC	105,400	17.3	8/1/2007	10/16/2024	68	Fair
TW	01	Taxiway	AAC	31,000	17.3	8/1/2007	10/16/2024	73	Satisfactory
TW	02	Taxiway	AAC	38,000	22.3	8/1/2002	10/16/2024	66	Fair
TW	04	Taxiway	AAC	52,850	22	11/1/2002	10/16/2024	30	Very Poor
TW	05	Taxiway	AAC	59,220	17.3	8/1/2007	10/16/2024	84	Satisfactory
TW	06	Taxiway	AAC	20,545	17.3	8/1/2007	10/16/2024	69	Fair
TW	07	Taxiway	AC	85,400	12.3	8/15/2012	10/16/2024	88	Good
AP	01	Apron	AAC	145,700	21.3	8/2/2003	10/16/2024	78	Satisfactory
AP	02	Apron	AAC	50,000	22.3	8/1/2002	10/16/2024	60	Fair

AIRFIELD PAVEMENT WORK HISTORY


- ADAP 03-R-1, TW:01, AP:01, ALL HEATER SCARIFIED AND CHIP SEALED.
- CBR=7 ASSUMED UNLESS OTHERWISE NOTED.
- EXTENDED 1968
- AIP-001-1986, OVERLAY RUNWAY 12/30, TAXIWAY, AND APRON.
- AIP-002-1988, CONSTRUCT RUNWAY 2/20.
- AIP-003-1989, EXTEND ACCESS TAXILANES; REHABILITATE PORTION OF PARALLEL TAXIWAY.
- AIP-004-2002, MILL AND OVERLAY APRON (AP:02), TAXIWAY (TW:02), AND TAXILANES (TW:04); CRACK SEAL, FOG SEAL, AND REMARK RUNWAY 12/30 AND TAXIWAY (TW:01).
- AIP-005-2003, MILL AND OVERLAY APRON (AP:01); OVERLAY RUNWAY (RW02:03).
- AIP-008-2007, MILL, OVERLAY, AND GROOVE RUNWAY 12/30 (RW12:01,RW12:02); CONSTRUCT TAXIWAY (TW:05) AND TURNAROUND (TW:06).
- AIP-011, 2012, CONSTRUCT TAXIWAY (TW:07).
- AIP-012-2013, CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS EXCEPT TW:07.
- AIP-017-2019, CRACK SEAL, SURFACE SEAL, REMARK ALL PAVEMENTS EXCEPT AP:02, TW:02, AND TW:04

MONTANA AVIATION SYSTEM PLAN
2024 PAVEMENT CONDITION INDEXES
 PREPARED FOR
Montana Department of Transportation
Division of Aeronautics



2024 Pavement Condition Index Map
GDV - DAWSON COMMUNITY AIRPORT

This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND


- BRANCH IDENTIFIER
- RW01:10** — SECTION IDENTIFIER
- SECTION BOUNDARY
- PCI 86-100 GOOD
- PCI 71-85 SATISFACTORY
- PCI 56-70 FAIR
- PCI 41-55 POOR
- PCI 26-40 VERY POOR
- PCI 11-25 SERIOUS
- PCI 0-10 FAILED

FORECASTED PAVEMENT CONDITION INDEX

Branch ID	Section ID	Surface Type	Current PCI (2024)	2025	2026	2027	2028	2029
RW02	03	AAC	71	71	70	69	68	66
RW12	01	AAC	67	67	65	63	61	59
RW12	02	AAC	68	68	66	65	63	61
TW	01	AAC	73	73	72	71	70	70
TW	02	AAC	66	66	65	64	62	61
TW	04	AAC	30	29	24	20	16	12
TW	05	AAC	84	84	82	80	79	77
TW	06	AAC	69	69	68	67	66	65
TW	07	AC	88	88	85	84	82	80
AP	01	AAC	78	78	76	74	73	72
AP	02	AAC	60	60	57	54	51	47



This document, together with the concepts and designs presented herein, is an instrument of service, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND

— BRANCH IDENTIFIER
RW01:10 SECTION IDENTIFIER
 — SECTION BOUNDARY

MAJOR REHABILITATION	GLOBAL TREATMENT
2025	2025
2026	2026
2027	2027
2028	2028
2029	2029

5-YEAR PAVEMENT NEEDS BY SECTION

Year	Branch ID	Section ID	Surface Type	Section Area (SF)	PCI at Treatment	Recommended Treatment	Treatment Category
2025	RW02	03	AAC	174,000	71	Crack Seal and Seal Coat	Global Treatment
2025	RW12	01	AAC	465,000	67	Mill and Overlay	Major Rehabilitation
2025	RW12	02	AAC	105,400	68	Mill and Overlay	Major Rehabilitation
2025	TW	01	AAC	31,000	73	Crack Seal and Seal Coat	Global Treatment
2025	TW	02	AAC	38,000	66	Mill and Overlay	Major Rehabilitation
2025	TW	04	AAC	52,850	29	Full-Depth Reconstruction	Major Rehabilitation
2025	TW	05	AAC	59,220	84	Crack Seal and Seal Coat	Global Treatment
2025	TW	06	AAC	20,545	69	Mill and Overlay	Major Rehabilitation
2025	TW	07	AC	85,400	88	Crack Seal and Seal Coat	Global Treatment
2025	AP	01	AAC	145,700	78	Crack Seal and Seal Coat	Global Treatment
2025	AP	02	AAC	50,000	60	Mill and Overlay	Major Rehabilitation



Runway



RW02-03-18: L&T Cracking



RW12-02-21: Weathering

Taxiway



TW-02-05: Raveling



TW-04-03: Bleeding

Apron



AP-01-21: L&T Cracking



AP-02-05: Patching

Re-Inspection Report

MDT SASP 2024

Generated Date 1/7/2025

Page 1 of 12

Network:	GDV	Name:	Dawson Community (Glendive) Airport		
Branch:	AP	Name:	Apron	Use:	APRON
		Area:	195,700 SqFt		
Section:	01	of 2	From:	STA 0+00A	To: STA 6+50A
			Last Const.:	8/2/2003	
Surface:	AAC	Family:	_MDT2024 - AP AAC	Zone:	GLEN
		Category:	H		
Area:	145,700 SqFt	Length:	2,914 Ft	Width:	50 Ft
Slabs:		Slab Length:	Ft	Slab Width:	Ft
		Joint Length:	Ft		
Shoulder:		Street Type:	ACA	Grade:	0
		Lanes:	0		

Section Comments:

Work Date:	8/15/1986	Work Type:	New Construction - Initial	Code:	NU-IN	Is Major M&R:	True
Work Date:	8/1/2003	Work Type:	Cold Milling	Code:	MI-CO	Is Major M&R:	False
Work Date:	8/2/2003	Work Type:	Overlay - AC Structural	Code:	OL-AS	Is Major M&R:	True
Work Date:	7/1/2020	Work Type:	Surface Seal	Code:	SS-LO	Is Major M&R:	False
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC	Code:	CS-AC	Is Major M&R:	False

Last Insp. Date: 10/16/2024 **TotalSamples:** 55 **Surveyed:** 5

Conditions: PCI: 78

Inspection Comments:

Sample Number:	03	Type:	R	Area:	4998.00 SqFt	PCI:	82
Sample Comments:							
45	DEPRESSION	L		4.00	SqFt		
48	L & T CR	L		139.00	Ft		
49	OIL SPILLAGE	N		40.00	SqFt		
57	WEATHERING	L		4998.00	SqFt		
Sample Number:	09	Type:	R	Area:	4998.00 SqFt	PCI:	78
Sample Comments:							
48	L & T CR	L		295.00	Ft		
57	WEATHERING	L		4998.00	SqFt		
Sample Number:	15	Type:	R	Area:	4998.00 SqFt	PCI:	73
Sample Comments:							
48	L & T CR	L		439.00	Ft		
57	WEATHERING	L		4998.00	SqFt		
Sample Number:	21	Type:	R	Area:	4998.00 SqFt	PCI:	79
Sample Comments:							
48	L & T CR	L		283.00	Ft		
57	WEATHERING	L		4998.00	SqFt		
Sample Number:	27	Type:	R	Area:	4806.00 SqFt	PCI:	78
Sample Comments:							
48	L & T CR	L		292.00	Ft		
57	WEATHERING	L		4806.00	SqFt		

Network: GDV **Name:** Dawson Community (Glendive) Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 195,700 SqFt

Section: 02 of 2 **From:** STA 6+50A **To:** STA 9+00A **Last Const.:** 8/1/2002

Surface: AAC **Family:** _MDT2024 - AP AAC **Zone:** GLEN **Category:** F **Rank:** P

Area: 50,000 SqFt **Length:** 1,000 Ft **Width:** 50 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACN **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 8/15/1986 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 8/1/2002 **Work Type:** Overlay - AC Thin **Code:** OL-AT **Is Major M&R:** True

Last Insp. Date: 10/16/2024 **Total Samples:** 20 **Surveyed:** 4

Conditions: PCI: 60

Inspection Comments:

Sample Number: 02 **Type:** R **Area:** 5198.00 SqFt **PCI:** 57

Sample Comments:

41 ALLIGATOR CR L 40.00 SqFt
48 L & T CR L 203.00 Ft
48 L & T CR M 100.00 Ft
53 RUTTING L 40.00 SqFt
57 WEATHERING L 2599.00 SqFt
57 WEATHERING M 2599.00 SqFt

Sample Number: 05 **Type:** R **Area:** 5000.00 SqFt **PCI:** 55

Sample Comments:

48 L & T CR L 400.00 Ft
48 L & T CR M 100.00 Ft
50 PATCHING M 8.00 SqFt
53 RUTTING L 4.00 SqFt
57 WEATHERING L 2492.00 SqFt
57 WEATHERING M 2496.00 SqFt

Sample Number: 08 **Type:** R **Area:** 4900.00 SqFt **PCI:** 58

Sample Comments:

48 L & T CR L 462.00 Ft
48 L & T CR M 100.00 Ft
53 RUTTING L 4.00 SqFt
57 WEATHERING L 2450.00 SqFt
57 WEATHERING M 2450.00 SqFt

Sample Number: 11 **Type:** R **Area:** 6000.00 SqFt **PCI:** 69

Sample Comments:

48 L & T CR L 277.00 Ft
48 L & T CR M 55.00 Ft
56 SWELLING L 4.00 SqFt
57 WEATHERING L 3000.00 SqFt
57 WEATHERING M 3000.00 SqFt

Network:	GDV	Name:	Dawson Community (Glendive) Airport						
Branch:	RW02	Name:	Runway 02-20	Use:	RUNWAY	Area:	174,000 SqFt		
Section:	03	of 1	From:	RWY 2-20 STA 0+00	To:	RWY 2-20 STA 30+00	Last Const.: 8/1/2003		
Surface:	AAC	Family:	_MDT2024 - RW AC AAC	Zone:	GLEN	Category:	E	Rank:	P
Area:	174,000 SqFt	Length:	2,900 Ft	Width:	60 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	7/31/1988	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	8/1/2003	Work Type:	Overlay - AC Thin		Code:	OL-AT	Is Major M&R:	True	
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	7/1/2020	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	10/16/2024	TotalSamples:	66	Surveyed:	6				
Conditions:	PCI: 71	Inspection Comments:							
Sample Number:	06	Type:	R	Area:	4800.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	316.00	Ft					
48	L & T CR	M	25.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	12	Type:	R	Area:	4800.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	320.00	Ft					
48	L & T CR	M	25.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	18	Type:	R	Area:	4800.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	259.00	Ft					
48	L & T CR	M	30.00	Ft					
48	L & T CR	H	30.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	24	Type:	R	Area:	4800.00 SqFt	PCI:	74		
Sample Comments:									
48	L & T CR	L	270.00	Ft					
48	L & T CR	M	30.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	30	Type:	R	Area:	4800.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	314.00	Ft					
48	L & T CR	M	30.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	36	Type:	R	Area:	4800.00 SqFt	PCI:	65		
Sample Comments:									
42	BLEEDING	N	40.00	SqFt					
48	L & T CR	L	293.00	Ft					
48	L & T CR	M	25.00	Ft					
57	WEATHERING	L	4560.00	SqFt					
57	WEATHERING	M	240.00	SqFt					

Network:	GDV		Name:	Dawson Community (Glendive) Airport					
Branch:	RW12	Name:	Runway 12-30	Use:	RUNWAY	Area:	570,400 SqFt		
Section:	01	of	2	From:	RWY 30-12 STA 6+00	To:	RWY 30-12 STA 52+50	Last Const.:	8/1/2007
Surface:	AAC	Family:	_MDT2024 - RW AC AAC	Zone:	GLEN	Category:	H	Rank:	P
Area:	465,000 SqFt	Length:	4,650 Ft	Width:	100 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACH	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/15/1986	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	8/1/2007	Work Type:	Overlay - AC Thin		Code:	OL-AT	Is Major M&R:	True	
Work Date:	7/1/2020	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Last Insp. Date:	10/16/2024	TotalSamples:	177	Surveyed:	7				
Conditions:	PCI:	67							
Inspection Comments:									
Sample Number:	05	Type:	R	Area:	5000.00 SqFt	PCI:	64		
Sample Comments:									
48	L & T CR	L	427.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	19	Type:	R	Area:	5000.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	276.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	33	Type:	R	Area:	5000.00 SqFt	PCI:	65		
Sample Comments:									
48	L & T CR	L	388.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	47	Type:	R	Area:	5000.00 SqFt	PCI:	67		
Sample Comments:									
48	L & T CR	L	344.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	61	Type:	R	Area:	5000.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	253.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	75	Type:	R	Area:	5000.00 SqFt	PCI:	66		
Sample Comments:									
42	BLEEDING	N	12.00	SqFt					
48	L & T CR	L	327.00	Ft					
48	L & T CR	M	75.00	Ft					
57	WEATHERING	L	4510.00	SqFt					
57	WEATHERING	M	500.00	SqFt					

Sample Number: 89

Type: R

Area: 5000.00 SqFt

PCI: 70

Sample Comments:

42	BLEEDING	N	20.00	SqFt
48	L & T CR	L	307.00	Ft
57	WEATHERING	L	4500.00	SqFt
57	WEATHERING	M	500.00	SqFt

Network:	GDV	Name:	Dawson Community (Glendive) Airport						
Branch:	RW12	Name:	Runway 12-30	Use:	RUNWAY	Area:	570,400 SqFt		
Section:	02	of 2	From:	RWY 30-12 STA 0+00/52+50	To:	RWY 30-12 STA 6+00/57+04	Last Const.:	8/1/2007	
Surface:	AAC	Family:	_MDT2024 - RW AC AAC	Zone:	GLEN	Category:	H	Rank:	P
Area:	105,400 SqFt	Length:	1,054 Ft	Width:	100 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACH	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/15/1986	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	8/1/2007	Work Type:	Overlay - AC Thin		Code:	OL-AT	Is Major M&R:	True	
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	7/1/2020	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	10/16/2024	TotalSamples:	38	Surveyed:	4				
Conditions:	PCI: 68								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	5000.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	217.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	12	Type:	R	Area:	5000.00 SqFt	PCI:	65		
Sample Comments:									
48	L & T CR	L	381.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	17	Type:	R	Area:	5000.00 SqFt	PCI:	70		
Sample Comments:									
42	BLEEDING	N	10.00	SqFt					
48	L & T CR	L	352.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	21	Type:	R	Area:	5000.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	421.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					

Network:	GDV		Name:	Dawson Community (Glendive) Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	287,015 SqFt		
Section:	01	of 6	From:	RUNWAY 12-30	To:	APRON	Last Const.:	8/1/2007	
Surface:	AAC	Family:	_MDT2024 - TW AAC	Zone:	GLEN	Category:	G	Rank:	P
Area:	31,000 SqFt	Length:	620 Ft	Width:	50 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACH	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/15/1986	Work Type:	New Construction - Initial	Code:	NU-IN	Is Major M&R:	True		
Work Date:	8/1/2007	Work Type:	Overlay - AC Thin	Code:	OL-AT	Is Major M&R:	True		
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC	Code:	CS-AC	Is Major M&R:	False		
Work Date:	7/1/2020	Work Type:	Surface Seal	Code:	SS-LO	Is Major M&R:	False		
Last Insp. Date:	10/16/2024	TotalSamples:	9	Surveyed:	3				
Conditions:	PCI:	73							
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	5599.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	432.00	Ft					
57	WEATHERING	L	5319.00	SqFt					
57	WEATHERING	M	280.00	SqFt					
Sample Number:	04	Type:	R	Area:	5599.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	427.00	Ft					
57	WEATHERING	L	5319.00	SqFt					
57	WEATHERING	M	280.00	SqFt					
Sample Number:	06	Type:	R	Area:	5599.00 SqFt	PCI:	77		
Sample Comments:									
42	BLEEDING	N	4.00	SqFt					
48	L & T CR	L	286.00	Ft					
57	WEATHERING	L	5319.00	SqFt					
57	WEATHERING	M	280.00	SqFt					

Network:	GDV		Name:	Dawson Community (Glendive) Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	287,015 SqFt		
Section:	02	of 6	From:	APRON	To:	RUNWAY 2-20	Last Const.:	8/1/2002	
Surface:	AAC	Family:	_MDT2024 - TW AAC	Zone:	GLEN	Category:	F	Rank:	P
Area:	38,000 SqFt	Length:	950 Ft	Width:	40 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/15/1986	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	8/1/2002	Work Type:	Overlay - AC Thin		Code:	OL-AT	Is Major M&R:	True	
Last Insp. Date:	10/16/2024	Total Samples:	12	Surveyed:	4				
Conditions:	PCI: 66								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	6996.00 SqFt	PCI:	64		
Sample Comments:									
41	ALLIGATOR CR	L	28.00	SqFt					
48	L & T CR	L	414.00	Ft					
48	L & T CR	M	150.00	Ft					
57	WEATHERING	L	3498.00	SqFt					
57	WEATHERING	M	3498.00	SqFt					
Sample Number:	03	Type:	R	Area:	6996.00 SqFt	PCI:	67		
Sample Comments:									
48	L & T CR	L	486.00	Ft					
48	L & T CR	M	125.00	Ft					
57	WEATHERING	L	3498.00	SqFt					
57	WEATHERING	M	3498.00	SqFt					
Sample Number:	05	Type:	R	Area:	6996.00 SqFt	PCI:	66		
Sample Comments:									
42	BLEEDING	N	4.00	SqFt					
48	L & T CR	L	293.00	Ft					
48	L & T CR	M	125.00	Ft					
52	RAVELING	M	5.00	SqFt					
57	WEATHERING	L	3496.00	SqFt					
57	WEATHERING	M	3496.00	SqFt					
Sample Number:	07	Type:	R	Area:	6996.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	397.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	3498.00	SqFt					
57	WEATHERING	M	3498.00	SqFt					

Network:	GDV		Name:	Dawson Community (Glendive) Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	287,015 SqFt		
Section:	04	of 6	From:	T-2	To:	HANGARS	Last Const.:	11/1/2002	
Surface:	AAC	Family:	_MDT2024 - TW AAC	Zone:		Category:		Rank:	P
Area:	52,850 SqFt	Length:	1,510 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:		Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	11/1/2002	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Last Insp. Date:	10/16/2024	TotalSamples:	18		Surveyed:	4			
Conditions:	PCI: 30								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	6000.00 SqFt	PCI:	61		
Sample Comments:									
42	BLEEDING	N	10.00	SqFt					
48	L & T CR	L	544.00	Ft					
48	L & T CR	M	200.00	Ft					
57	WEATHERING	M	6000.00	SqFt					
Sample Number:	03	Type:	R	Area:	5495.00 SqFt	PCI:	20		
Sample Comments:									
42	BLEEDING	N	4121.00	SqFt					
48	L & T CR	L	75.00	Ft					
48	L & T CR	M	30.00	Ft					
52	RAVELING	M	5.00	SqFt					
57	WEATHERING	L	5490.00	SqFt					
Sample Number:	07	Type:	R	Area:	5495.00 SqFt	PCI:	19		
Sample Comments:									
42	BLEEDING	N	5495.00	SqFt					
48	L & T CR	L	158.00	Ft					
48	L & T CR	M	50.00	Ft					
57	WEATHERING	M	5495.00	SqFt					
Sample Number:	09	Type:	R	Area:	5500.00 SqFt	PCI:	18		
Sample Comments:									
42	BLEEDING	N	4950.00	SqFt					
48	L & T CR	L	105.00	Ft					
48	L & T CR	M	30.00	Ft					
52	RAVELING	H	10.00	SqFt					
57	WEATHERING	M	5490.00	SqFt					

Network:	GDV		Name:	Dawson Community (Glendive) Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	287,015 SqFt		
Section:	05	of 6	From:	RUNWAY 12-30	To:	RUNWAY 2-20	Last Const.:	8/1/2007	
Surface:	AAC	Family:	_MDT2024 - TW AAC	Zone:	GLEN	Category:	D	Rank:	P
Area:	59,220 SqFt	Length:	1,692 Ft	Width:	35 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2007	Work Type:	New Construction - Initial	Code:	NU-IN	Is Major M&R:	True		
Work Date:	7/1/2020	Work Type:	Surface Seal	Code:	SS-LO	Is Major M&R:	False		
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC	Code:	CS-AC	Is Major M&R:	False		
Last Insp. Date:	10/16/2024	TotalSamples:	20	Surveyed:	4				
Conditions:	PCI:	84							
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	4935.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	213.00	Ft					
57	WEATHERING	L	4935.00	SqFt					
Sample Number:	04	Type:	R	Area:	4935.00 SqFt	PCI:	84		
Sample Comments:									
48	L & T CR	L	167.00	Ft					
57	WEATHERING	L	4935.00	SqFt					
Sample Number:	07	Type:	R	Area:	4935.00 SqFt	PCI:	86		
Sample Comments:									
48	L & T CR	L	127.00	Ft					
57	WEATHERING	L	4935.00	SqFt					
Sample Number:	10	Type:	R	Area:	4935.00 SqFt	PCI:	85		
Sample Comments:									
48	L & T CR	L	140.00	Ft					
57	WEATHERING	L	4935.00	SqFt					

Network:	GDV		Name:	Dawson Community (Glendive) Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	287,015 SqFt		
Section:	06	of 6	From:	RUNWAY 12-30	To:	JUGHANDLE	Last Const.:	8/1/2007	
Surface:	AAC	Family:	_MDT2024 - TW AAC	Zone:	GLEN	Category:	D	Rank:	P
Area:	20,545 SqFt	Length:	587 Ft	Width:	35 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2007	Work Type:	New Construction - Initial	Code:	NU-IN	Is Major M&R:	True		
Work Date:	7/1/2020	Work Type:	Surface Seal	Code:	SS-LO	Is Major M&R:	False		
Work Date:	7/1/2020	Work Type:	Crack Sealing - AC	Code:	CS-AC	Is Major M&R:	False		
Last Insp. Date:	10/16/2024	TotalSamples:	9	Surveyed:	3				
Conditions:	PCI: 69								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	4244.00 SqFt	PCI:	65		
Sample Comments:									
48	L & T CR	L	174.00	Ft					
48	L & T CR	M	150.00	Ft					
57	WEATHERING	L	4032.00	SqFt					
57	WEATHERING	M	212.00	SqFt					
Sample Number:	04	Type:	R	Area:	3965.00 SqFt	PCI:	69		
Sample Comments:									
48	L & T CR	L	150.00	Ft					
48	L & T CR	M	102.00	Ft					
57	WEATHERING	L	3767.00	SqFt					
57	WEATHERING	M	198.00	SqFt					
Sample Number:	06	Type:	R	Area:	5043.00 SqFt	PCI:	73		
Sample Comments:									
48	L & T CR	L	221.00	Ft					
48	L & T CR	M	22.00	Ft					
57	WEATHERING	L	4791.00	SqFt					
57	WEATHERING	M	252.00	SqFt					

Network:	GDV	Name:	Dawson Community (Glendive) Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	287,015 SqFt		
Section:	07	of 6	From:	A-1	To:	T-6	Last Const.: 8/15/2012		
Surface:	AC	Family:	_MDT2024 - TW AC	Zone:	GLEN	Category:	D	Rank:	P
Area:	85,400 SqFt	Length:	2,440 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/15/2012	Work Type: New Construction - Initial			Code:	NU-IN	Is Major M&R: True		
Work Date:	7/1/2020	Work Type: Surface Seal			Code:	SS-LO	Is Major M&R: False		
Work Date:	7/1/2020	Work Type: Crack Sealing - AC			Code:	CS-AC	Is Major M&R: False		
Last Insp. Date:	10/16/2024	TotalSamples:	30	Surveyed:	6				
Conditions:	PCI: 88								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	6758.00 SqFt	PCI:	86		
Sample Comments:									
48	L & T CR	L	78.00	Ft					
57	WEATHERING	L	6420.00	SqFt					
57	WEATHERING	M	338.00	SqFt					
Sample Number:	05	Type:	R	Area:	6199.00 SqFt	PCI:	86		
Sample Comments:									
48	L & T CR	L	33.00	Ft					
57	WEATHERING	L	5889.00	SqFt					
57	WEATHERING	M	310.00	SqFt					
Sample Number:	07	Type:	R	Area:	5985.00 SqFt	PCI:	85		
Sample Comments:									
48	L & T CR	L	100.00	Ft					
57	WEATHERING	L	5686.00	SqFt					
57	WEATHERING	M	299.00	SqFt					
Sample Number:	09	Type:	R	Area:	5772.00 SqFt	PCI:	91		
Sample Comments:									
57	WEATHERING	L	5483.00	SqFt					
57	WEATHERING	M	289.00	SqFt					
Sample Number:	13	Type:	R	Area:	5345.00 SqFt	PCI:	91		
Sample Comments:									
57	WEATHERING	L	5078.00	SqFt					
57	WEATHERING	M	267.00	SqFt					
Sample Number:	17	Type:	R	Area:	4721.00 SqFt	PCI:	88		
Sample Comments:									
48	L & T CR	L	79.00	Ft					
57	WEATHERING	L	4721.00	SqFt					