


This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND

—	BRANCH IDENTIFIER
—	SECTION IDENTIFIER
—	SECTION BOUNDARY
■ (Green)	PCI 86-100 GOOD
■ (Light Green)	PCI 71-85 SATISFACTORY
■ (Yellow)	PCI 56-70 FAIR
■ (Orange)	PCI 41-55 POOR
■ (Pink)	PCI 26-40 VERY POOR
■ (Red)	PCI 11-25 SERIOUS
■ (Grey)	PCI 0-10 FAILED

CURRENT 2021 PAVEMENT CONDITION INDEX

Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
AP	03A	Apron	AAC	55,000	14.4	8/1/2007	8/26/2021	67	Fair
AP	11	Apron	PCC	80,156	17.4	8/1/2004	8/26/2021	84	Satisfactory
AP	12	Apron	AC	21,000	17.4	8/1/2004	8/26/2021	77	Satisfactory
AP	13	Apron	AAC	114,774	15.4	8/1/2006	8/26/2021	67	Fair
AP	14	Apron	PCC	30,000	15.4	8/1/2006	8/26/2021	82	Satisfactory
AP	15	Apron	PCC	9,375	15.4	8/1/2006	8/26/2021	90	Good
RW01	12	Runway 01-19	AAC	570,500	18.4	8/1/2003	8/26/2021	71	Satisfactory
RW11	11	Runway 11-29	AAC	402,000	18.4	8/1/2003	8/26/2021	71	Satisfactory
TW	02	Taxiway	AC	30,000	1.1	11/1/2020	11/1/2020	100	Good
TW	04	Taxiway	AAC	338,250	9.2	9/30/2012	8/26/2021	77	Satisfactory
TW	05	Taxiway	AC	7,000	24.2	10/1/1997	8/26/2021	38	Very Poor
TW	06	Taxiway	AC	58,450	9.4	8/1/2012	8/26/2021	87	Good
TW	07	Taxiway	AC	111,016	5.3	9/10/2016	8/26/2021	89	Good
TW	08	Taxiway	AC	51,695	1.1	11/1/2020	11/1/2020	100	Good
TW	09	Taxiway	AC	8,000	1.1	11/1/2020	11/1/2020	100	Good
TW	10	Taxiway	AC	8,600	1.1	11/1/2020	11/1/2020	100	Good

AIRFIELD PAVEMENT WORK HISTORY

- ADAP-05, 1980, RESURFACE RUNWAY 10/28; APRON OVERLAY AND EXPANSION.
- AIP-001-1984, REHABILITATE RUNWAY 1/19, APRON, AND TAXIWAYS; EXPAND APRON (AP:02,AP:03); CONSTRUCT HELIPAD (AP:05).
- AIP-005-1992, CONSTRUCT PARALLEL TAXIWAY.
- AIP-007-1997, OVERLAY TAXIWAY (TW:02); RECONSTRUCT TAXIWAY (TW:05).
- AIP-011-2003, OVERLAY AND GROOVE RUNWAYS; CRACK SEAL, FOG SEAL, AND REMARK TAXIWAY (TW:04).
- AIP-012-2004, CONSTRUCT APRONS (AP:11,AP:12).
- AIP-013-2005, CONSTRUCT APRON (AP:14).
- AIP-014-2006, RECONSTRUCT APRONS (AP:13, AP:15); CONSTRUCT HELIPAD (AP:05A, EXEMPT); REMOVE HELIPAD (AP:05).
- AIP-015-2007, RECONSTRUCT APRON (AP:03A).
- AIP-017-2010, CRACK SEAL, FOG SEAL, AND REMARK RUNWAYS AND TAXIWAYS.
- AIP-019-2012, OVERLAY TAXIWAY D (TW:04); CONSTRUCT TAXIWAY C (TW:06).
- AIP-020-2014, CRACK SEAL, SEAL COAT, AND REMARK PAVEMENTS.
- AIP-022-2015, CONSTRUCT TAXIWAYS (TW:07). [PAVEMENT SECTION COMPLETED 2016]
- AIP-024-2019, CRACK SEAL, SURFACE SEAL, REMARK ALL PAVEMENTS.
- AIP-026-2020, RECONSTRUCT TAXIWAY E (TW:02), NEW TAXIWAY B EXTENSION (TW:08), AND TAXIWAY B CONNECTOR CONSTRUCTION (TW:09, TW:10).

Runway



RW11-11-79: Raveling



RW01-12-97: Weathering

Taxiway



TW05-01: Alligator Cracking



TW05-01: Rutting

Apron



AP11-23: Popouts



AP-15-05: Corner Break



AP03A-03: L&T Cracking



AP12-03: Patching

Re-Inspection Report

MDT SASP 2021

Generated Date 12/17/2021

Page 1 of 13

Network: SDY **Name:** Sidney-Richland Regional Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 310,305 SqFt

Section: 03A of 6 **From:** A-13 and A-15 **To:** T-3 **Last Const.:** 8/1/2007

Surface: AAC **Family:** DEFAULT **Zone:** SIDN **Category:** D **Rank:** P

Area: 55,000 SqFt **Length:** 450 Ft **Width:** 140 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACN **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 8/1/2007 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 7/1/2019 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

Work Date: 7/1/2019 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

Last Insp. Date: 8/26/2021 **TotalSamples:** 11 **Surveyed:** 4

Conditions: PCI: 67

Inspection Comments:

Sample Number: 03 **Type:** R **Area:** 5250.00 SqFt **PCI:** 64

Sample Comments:

48 L & T CR L 635.00 Ft
 57 WEATHERING L 4725.00 SqFt
 57 WEATHERING M 525.00 SqFt

Sample Number: 06 **Type:** R **Area:** 5250.00 SqFt **PCI:** 65

Sample Comments:

48 L & T CR L 599.00 Ft
 57 WEATHERING L 4725.00 SqFt
 57 WEATHERING M 525.00 SqFt

Sample Number: 08 **Type:** R **Area:** 5250.00 SqFt **PCI:** 73

Sample Comments:

48 L & T CR L 308.00 Ft
 57 WEATHERING L 4725.00 SqFt
 57 WEATHERING M 525.00 SqFt

Sample Number: 09 **Type:** R **Area:** 5250.00 SqFt **PCI:** 64

Sample Comments:

48 L & T CR L 640.00 Ft
 57 WEATHERING L 4725.00 SqFt
 57 WEATHERING M 525.00 SqFt

Network:	SDY	Name:	Sidney-Richland Regional Airport				
Branch:	AP	Name:	Apron	Use:	APRON	Area:	310,305 SqFt
Section:	11	of 6	From:	A-14 & A-15	To:	A-12	Last Const.: 8/1/2004
Surface:	PCC	Family:	DEFAULT	Zone:	SIDN	Category:	P
Area:	80,156 SqFt	Length:	238 Ft	Width:	338 Ft		
Slabs:	513	Slab Length:	12 Ft	Slab Width:	12 Ft	Joint Length:	12,295 Ft
Shoulder:		Street Type:	PCA	Grade:	0	Lanes:	0
Section Comments:							
Work Date:	8/1/2004	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R: True
Work Date:	1/1/2018	Work Type:	Joint Seal (Localized)		Code:	JS-LC	Is Major M&R: False
Last Insp. Date:	8/26/2021	Total Samples:	27	Surveyed:	7		
Conditions:	PCI: 84						
Inspection Comments:							
Sample Number:	05	Type:	R	Area:	19.00 Slabs	PCI:	83
Sample Comments:							
68	POPOUTS		N	6.00	Slabs		
73	SHRINKAGE CR		N	1.00	Slabs		
Sample Number:	08	Type:	R	Area:	19.00 Slabs	PCI:	84
Sample Comments:							
68	POPOUTS		N	5.00	Slabs		
74	JOINT SPALL		L	1.00	Slabs		
Sample Number:	11	Type:	R	Area:	19.00 Slabs	PCI:	87
Sample Comments:							
74	JOINT SPALL		H	1.00	Slabs		
Sample Number:	14	Type:	R	Area:	19.00 Slabs	PCI:	88
Sample Comments:							
68	POPOUTS		N	4.00	Slabs		
Sample Number:	17	Type:	R	Area:	19.00 Slabs	PCI:	79
Sample Comments:							
68	POPOUTS		N	6.00	Slabs		
75	CORNER SPALL		H	1.00	Slabs		
Sample Number:	20	Type:	R	Area:	19.00 Slabs	PCI:	83
Sample Comments:							
68	POPOUTS		N	7.00	Slabs		
Sample Number:	23	Type:	R	Area:	19.00 Slabs	PCI:	81
Sample Comments:							
68	POPOUTS		N	7.00	Slabs		
75	CORNER SPALL		L	1.00	Slabs		

Network: SDY **Name:** Sidney-Richland Regional Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 310,305 SqFt

Section: 12 of 6 **From:** A-11 **To:** A-13 **Last Const.:** 8/1/2004

Surface: AC **Family:** DEFAULT **Zone:** SIDN **Category:** G **Rank:** P

Area: 21,000 SqFt **Length:** 250 Ft **Width:** 84 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACA **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 8/1/2004 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 7/1/2019 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

Work Date: 7/1/2019 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

Last Insp. Date: 8/26/2021 **TotalSamples:** 4 **Surveyed:** 3

Conditions: PCI: 77

Inspection Comments:

Sample Number: 01 **Type:** R **Area:** 5250.00 SqFt **PCI:** 81

Sample Comments:

48 L & T CR L 133.00 Ft

57 WEATHERING L 4725.00 SqFt

57 WEATHERING M 525.00 SqFt

Sample Number: 03 **Type:** R **Area:** 5250.00 SqFt **PCI:** 74

Sample Comments:

48 L & T CR L 91.00 Ft

50 PATCHING M 72.00 SqFt

57 WEATHERING L 4653.00 SqFt

57 WEATHERING M 518.00 SqFt

Sample Number: 04 **Type:** R **Area:** 5250.00 SqFt **PCI:** 75

Sample Comments:

48 L & T CR L 256.00 Ft

57 WEATHERING L 4725.00 SqFt

57 WEATHERING M 525.00 SqFt

Network:	SDY	Name:	Sidney-Richland Regional Airport				
Branch:	AP	Name:	Apron	Use:	APRON	Area:	310,305 SqFt
Section:	13	of 6	From:	T-2	To:	A-3A	Last Const.: 8/1/2006
Surface:	AAC	Family:	DEFAULT	Zone:	SIDN	Category:	G
Area:	114,774 SqFt	Length:	660 Ft	Width:	135 Ft	Rank:	P
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft	
Shoulder:	Street Type:	ACA	Grade:	0	Lanes:	0	
Section Comments:							
Work Date:	8/1/2006	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R: True
Work Date:	7/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R: False
Work Date:	7/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R: False
Last Insp. Date:	8/26/2021	TotalSamples:	24	Surveyed:	5		
Conditions:	PCI: 67	Inspection Comments:					
Sample Number:	05	Type:	R	Area:	5520.00 SqFt	PCI:	69
Sample Comments:							
48	L & T CR	L	322.00	Ft			
48	L & T CR	M	50.00	Ft			
52	RAVELING	L	1380.00	SqFt			
57	WEATHERING	L	4140.00	SqFt			
Sample Number:	10	Type:	R	Area:	4680.00 SqFt	PCI:	63
Sample Comments:							
48	L & T CR	L	434.00	Ft			
48	L & T CR	M	50.00	Ft			
52	RAVELING	L	1170.00	SqFt			
57	WEATHERING	L	3510.00	SqFt			
Sample Number:	15	Type:	R	Area:	4680.00 SqFt	PCI:	66
Sample Comments:							
48	L & T CR	L	342.00	Ft			
48	L & T CR	M	50.00	Ft			
52	RAVELING	L	936.00	SqFt			
57	WEATHERING	L	3744.00	SqFt			
Sample Number:	20	Type:	R	Area:	5460.00 SqFt	PCI:	70
Sample Comments:							
48	L & T CR	L	607.00	Ft			
57	WEATHERING	M	546.00	SqFt			
Sample Number:	23	Type:	R	Area:	5460.00 SqFt	PCI:	68
Sample Comments:							
48	L & T CR	L	504.00	Ft			
57	WEATHERING	L	4641.00	SqFt			
57	WEATHERING	M	819.00	SqFt			

Network: SDY **Name:** Sidney-Richland Regional Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 310,305 SqFt

Section: 14 of 6 **From:** A-11 **To:** A-3A and A-15 **Last Const.:** 8/1/2006

Surface: PCC **Family:** DEFAULT **Zone:** SIDN **Category:** P **Rank:** P

Area: 30,000 SqFt **Length:** 300 Ft **Width:** 100 Ft

Slabs: 192 **Slab Length:** 12 Ft **Slab Width:** 12 Ft **Joint Length:** 4,400 Ft

Shoulder: **Street Type:** PCA **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 8/1/2006 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 1/1/2018 **Work Type:** Joint Seal (Localized) **Code:** JS-LC **Is Major M&R:** False

Last Insp. Date: 8/26/2021 **Total Samples:** 12 **Surveyed:** 7

Conditions: PCI: 82

Inspection Comments:

Sample Number: 02 **Type:** R **Area:** 16.00 Slabs **PCI:** 84

Sample Comments:

68 POPOUTS N 5.00 Slabs

Sample Number: 04 **Type:** R **Area:** 16.00 Slabs **PCI:** 84

Sample Comments:

68 POPOUTS N 5.00 Slabs

Sample Number: 06 **Type:** R **Area:** 16.00 Slabs **PCI:** 79

Sample Comments:

68 POPOUTS N 10.00 Slabs

Sample Number: 08 **Type:** R **Area:** 16.00 Slabs **PCI:** 83

Sample Comments:

68 POPOUTS N 6.00 Slabs

Sample Number: 10 **Type:** R **Area:** 16.00 Slabs **PCI:** 79

Sample Comments:

68 POPOUTS N 10.00 Slabs

Sample Number: 11 **Type:** R **Area:** 16.00 Slabs **PCI:** 83

Sample Comments:

68 POPOUTS N 6.00 Slabs

Sample Number: 12 **Type:** R **Area:** 24.00 Slabs **PCI:** 81

Sample Comments:

68 POPOUTS N 11.00 Slabs

Network: SDY **Name:** Sidney-Richland Regional Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 310,305 SqFt

Section: 15 of 6 **From:** SOUTHWESTERN APRON **To:** A-11 AND A-14 **Last Const.:** 8/1/2006

Surface: PCC **Family:** DEFAULT **Zone:** SIDN **Category:** P **Rank:** P

Area: 9,375 SqFt **Length:** 300 Ft **Width:** 28 Ft

Slabs: 82 **Slab Length:** 12 Ft **Slab Width:** 9 Ft **Joint Length:** 1,256 Ft

Shoulder: **Street Type:** PCA **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 8/1/2006 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 1/1/2018 **Work Type:** Joint Seal (Localized) **Code:** JS-LC **Is Major M&R:** False

Last Insp. Date: 8/26/2021 **TotalSamples:** 5 **Surveyed:** 4

Conditions: PCI: 90

Inspection Comments:

Sample Number: 01 **Type:** R **Area:** 20.00 Slabs **PCI:** 93

Sample Comments:

68 POPOUTS N 2.00 Slabs

Sample Number: 02 **Type:** R **Area:** 14.00 Slabs **PCI:** 80

Sample Comments:

68 POPOUTS N 7.00 Slabs

Sample Number: 04 **Type:** R **Area:** 18.00 Slabs **PCI:** 100

Sample Comments:

<No Distress>

Sample Number: 05 **Type:** R **Area:** 12.00 Slabs **PCI:** 80

Sample Comments:

62 CORNER BREAK H 1.00 Slabs

Network:	SDY	Name:	Sidney-Richland Regional Airport						
Branch:	RW01	Name:	Runway 01-19	Use:	RUNWAY	Area:	570,500 SqFt		
Section:	12	of	1	From:	RWY 1-19 STA 0+00	To:	RWY 1-19 STA 57+05	Last Const.:	8/1/2003
Surface:	AAC	Family:	DEFAULT	Zone:	SIDN	Category:	H	Rank:	P
Area:	570,500 SqFt	Length:	5,705 Ft	Width:	100 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACH	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/2003	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	7/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Work Date:	7/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Last Insp. Date:	8/26/2021	TotalSamples:	112	Surveyed:	7				
Conditions:	PCI: 71								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	5000.00 SqFt	PCI:	68		
Sample Comments:									
48	L & T CR	L	333.00	Ft					
52	RAVELING	L	100.00	SqFt					
57	WEATHERING	L	4410.00	SqFt					
57	WEATHERING	M	490.00	SqFt					
Sample Number:	17	Type:	R	Area:	5000.00 SqFt	PCI:	71		
Sample Comments:									
48	L & T CR	L	358.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	33	Type:	R	Area:	5000.00 SqFt	PCI:	70		
Sample Comments:									
48	L & T CR	L	268.00	Ft					
48	L & T CR	M	5.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	49	Type:	R	Area:	5000.00 SqFt	PCI:	70		
Sample Comments:									
48	L & T CR	L	395.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	65	Type:	R	Area:	5000.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	335.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	81	Type:	R	Area:	5000.00 SqFt	PCI:	75		
Sample Comments:									
48	L & T CR	L	258.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	97	Type:	R	Area:	5000.00 SqFt	PCI:	71		
Sample Comments:									
48	L & T CR	L	350.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					

Network:	SDY	Name:	Sidney-Richland Regional Airport						
Branch:	RW11	Name:	Runway 11-29	Use:	RUNWAY	Area:	402,000 SqFt		
Section:	11	of	1	From:	RWY 28-10 STA 0+00	To:	RWY 28-10 STA 40+20	Last Const.:	8/1/2003
Surface:	AAC	Family:	DEFAULT	Zone:	SIDN	Category:	H	Rank:	P
Area:	402,000 SqFt	Length:	4,020 Ft	Width:	100 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACH	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/2003	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	7/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Work Date:	7/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Last Insp. Date:	8/26/2021	TotalSamples:	80	Surveyed:	7				
Conditions:	PCI: 71								
Inspection Comments:									
Sample Number:	06	Type:	R	Area:	5000.00 SqFt	PCI:	77		
Sample Comments:									
48	L & T CR	L	239.00	Ft					
57	WEATHERING	L	4750.00	SqFt					
57	WEATHERING	M	250.00	SqFt					
Sample Number:	18	Type:	R	Area:	5000.00 SqFt	PCI:	73		
Sample Comments:									
48	L & T CR	L	333.00	Ft					
57	WEATHERING	L	4750.00	SqFt					
57	WEATHERING	M	250.00	SqFt					
Sample Number:	30	Type:	R	Area:	5000.00 SqFt	PCI:	64		
Sample Comments:									
48	L & T CR	L	416.00	Ft					
48	L & T CR	M	30.00	Ft					
57	WEATHERING	L	4000.00	SqFt					
57	WEATHERING	M	1000.00	SqFt					
Sample Number:	42	Type:	R	Area:	5000.00 SqFt	PCI:	71		
Sample Comments:									
48	L & T CR	L	364.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	54	Type:	R	Area:	5000.00 SqFt	PCI:	70		
Sample Comments:									
48	L & T CR	L	405.00	Ft					
57	WEATHERING	L	4500.00	SqFt					
57	WEATHERING	M	500.00	SqFt					
Sample Number:	66	Type:	R	Area:	5000.00 SqFt	PCI:	75		
Sample Comments:									
48	L & T CR	L	300.00	Ft					
57	WEATHERING	L	4750.00	SqFt					
57	WEATHERING	M	250.00	SqFt					
Sample Number:	79	Type:	R	Area:	5000.00 SqFt	PCI:	67		
Sample Comments:									
48	L & T CR	L	226.00	Ft					
48	L & T CR	M	75.00	Ft					
52	RAVELING	M	10.00	SqFt					
57	WEATHERING	L	3493.00	SqFt					
57	WEATHERING	M	1497.00	SqFt					

Network: SDY **Name:** Sidney-Richland Regional Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 613,011 SqFt

Section: 02 of 8 **From:** RWY 28-10 STA 7+50 **To:** APRON **Last Const.:** 11/1/2020

Surface: AC **Family:** DEFAULT **Zone:** SIDN **Category:** H **Rank:** P

Area: 30,000 SqFt **Length:** 750 Ft **Width:** 40 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACH **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 9/1/1997 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 11/1/2020 **Work Type:** Complete Reconstruction - AC **Code:** CR-AC **Is Major M&R:** True

Last Insp. Date: 9/27/2018 **Total Samples:** 5 **Surveyed:** 3

Conditions: PCI: 55 **NOTE: *** Pre-Construction PCI *****

Inspection Comments:

Sample Number: 001 **Type:** R **Area:** 5000.00 SqFt **PCI:** 48

Sample Comments:

48 L & T CR L 300.00 Ft
48 L & T CR M 67.00 Ft
52 RAVELING H 190.00 SqFt
57 WEATHERING L 5000.00 SqFt

Sample Number: 003 **Type:** R **Area:** 5000.00 SqFt **PCI:** 70

Sample Comments:

45 DEPRESSION L 35.00 SqFt
48 L & T CR L 180.00 Ft
48 L & T CR M 70.00 Ft
50 PATCHING L .18 SqFt
57 WEATHERING L 5000.00 SqFt

Sample Number: 005 **Type:** R **Area:** 5000.00 SqFt **PCI:** 47

Sample Comments:

45 DEPRESSION L 20.00 SqFt
45 DEPRESSION M 10.00 SqFt
48 L & T CR L 297.00 Ft
48 L & T CR M 98.00 Ft
52 RAVELING H 180.00 SqFt

Network:	SDY	Name:	Sidney-Richland Regional Airport				
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	613,011 SqFt
Section:	04	of 8	From:	PARALLEL to RWY 1/19	To:		Last Const.: 9/30/2012
Surface:	AAC	Family:	DEFAULT	Zone:	SIDN	Category:	G
Area:	338,250 SqFt	Length:	6,150 Ft	Width:	55 Ft	Rank:	P
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft
Shoulder:		Street Type:	ACH	Grade:	0	Lanes:	0
Section Comments:							
Work Date:	9/30/1992	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R: True
Work Date:	9/30/2012	Work Type:	Overlay - Asphalt		Code:	OL-AC	Is Major M&R: True
Work Date:	7/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R: False
Work Date:	7/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R: False
Last Insp. Date:	8/26/2021	TotalSamples:	61	Surveyed:	6		
Conditions:	PCI: 77						
Inspection Comments:							
Sample Number:	02	Type:	R	Area:	5500.00 SqFt	PCI:	74
Sample Comments:							
48	L & T CR	L	233.00	Ft			
52	RAVELING	L	50.00	SqFt			
57	WEATHERING	L	4905.00	SqFt			
57	WEATHERING	M	545.00	SqFt			
Sample Number:	13	Type:	R	Area:	5500.00 SqFt	PCI:	80
Sample Comments:							
48	L & T CR	L	271.00	Ft			
57	WEATHERING	L	5500.00	SqFt			
Sample Number:	24	Type:	R	Area:	5500.00 SqFt	PCI:	79
Sample Comments:							
48	L & T CR	L	309.00	Ft			
57	WEATHERING	L	5500.00	SqFt			
Sample Number:	35	Type:	R	Area:	5500.00 SqFt	PCI:	73
Sample Comments:							
48	L & T CR	L	375.00	Ft			
57	WEATHERING	L	5225.00	SqFt			
57	WEATHERING	M	275.00	SqFt			
Sample Number:	45	Type:	R	Area:	5500.00 SqFt	PCI:	75
Sample Comments:							
48	L & T CR	L	310.00	Ft			
57	WEATHERING	L	5225.00	SqFt			
57	WEATHERING	M	275.00	SqFt			
Sample Number:	57	Type:	R	Area:	5500.00 SqFt	PCI:	81
Sample Comments:							
48	L & T CR	L	255.00	Ft			
57	WEATHERING	L	5500.00	SqFt			

Network: SDY **Name:** Sidney-Richland Regional Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 613,011 SqFt

Section: 05 of 8 **From:** A-4 **To:** R-1 **Last Const.:** 10/1/1997

Surface: AC **Family:** DEFAULT **Zone:** SIDN **Category:** G **Rank:** P

Area: 7,000 SqFt **Length:** 140 Ft **Width:** 50 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACH **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 10/1/1997 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 7/1/2019 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

Work Date: 7/1/2019 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

Last Insp. Date: 8/26/2021 **TotalSamples:** 1 **Surveyed:** 1

Conditions: PCI: 38

Inspection Comments:

Sample Number: 01 **Type:** R **Area:** 7000.00 SqFt **PCI:** 38

Sample Comments:

41	ALLIGATOR CR	L	134.00	SqFt
41	ALLIGATOR CR	M	12.00	SqFt
42	BLEEDING	N	15.00	SqFt
48	L & T CR	L	559.00	Ft
48	L & T CR	M	100.00	Ft
53	RUTTING	L	150.00	SqFt
56	SWELLING	M	16.00	SqFt
57	WEATHERING	L	5600.00	SqFt
57	WEATHERING	M	1400.00	SqFt

Network:	SDY	Name:	Sidney-Richland Regional Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	613,011 SqFt		
Section:	06	of 8	From:	R-12	To:	T-4	Last Const.:	8/1/2012	
Surface:	AC	Family:	DEFAULT	Zone:		Category:		Rank:	P
Area:	58,450 SqFt	Length:	1,670 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACH	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/2012	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	7/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	7/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	8/26/2021	TotalSamples:	12	Surveyed:	4				
Conditions:	PCI: 87								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	5000.00 SqFt	PCI:	88		
Sample Comments:									
57	WEATHERING		L	4250.00	SqFt				
57	WEATHERING		M	750.00	SqFt				
Sample Number:	05	Type:	R	Area:	4900.00 SqFt	PCI:	87		
Sample Comments:									
48	L & T CR		L	25.00	Ft				
57	WEATHERING		L	4655.00	SqFt				
57	WEATHERING		M	245.00	SqFt				
Sample Number:	08	Type:	R	Area:	4900.00 SqFt	PCI:	91		
Sample Comments:									
57	WEATHERING		L	4655.00	SqFt				
57	WEATHERING		M	245.00	SqFt				
Sample Number:	11	Type:	R	Area:	4900.00 SqFt	PCI:	84		
Sample Comments:									
48	L & T CR		L	100.00	Ft				
57	WEATHERING		L	4655.00	SqFt				
57	WEATHERING		M	245.00	SqFt				

Network:	SDY	Name:	Sidney-Richland Regional Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	613,011 SqFt		
Section:	07	of 8	From:	T-6 & T-4	To:	HANGARS	Last Const.:	9/10/2016	
Surface:	AC	Family:	DEFAULT	Zone:		Category:		Rank:	P
Area:	111,016 SqFt	Length:	3,140 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:		Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	9/10/2016	Work Type:	New Construction - AC		Code:	NC-AC	Is Major M&R:	True	
Work Date:	7/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	7/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	8/26/2021	TotalSamples:	22		Surveyed:	5			
Conditions:	PCI: 89								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	4865.00 SqFt	PCI:	85		
Sample Comments:									
48	L & T CR	L	139.00	Ft					
57	WEATHERING	L	4865.00	SqFt					
Sample Number:	08	Type:	R	Area:	4865.00 SqFt	PCI:	88		
Sample Comments:									
48	L & T CR	L	94.00	Ft					
57	WEATHERING	L	4865.00	SqFt					
Sample Number:	14	Type:	R	Area:	4350.00 SqFt	PCI:	80		
Sample Comments:									
48	L & T CR	L	232.00	Ft					
57	WEATHERING	L	4350.00	SqFt					
Sample Number:	17	Type:	R	Area:	5425.00 SqFt	PCI:	94		
Sample Comments:									
57	WEATHERING	L	5425.00	SqFt					
Sample Number:	22	Type:	R	Area:	5425.00 SqFt	PCI:	94		
Sample Comments:									
57	WEATHERING	L	5425.00	SqFt					